



Addendum # 1

Repair by replacing Hook Range CTA:

This addendum #1 shall change, add or substitute the requirements to the SOW and drawing and specifications as if it were issued with the originals and the invitation for bid proposals.

The bidding contractors shall provide all labor, supervision, material and equipment to perform the following items of work:

1. Replace existing electric hand-hole as indicated on the drawing sheet 44117-E0, Keyed Note #3 with a new electric hand-hole.
2. The new electric hand-hole shall match existing hand-hole dimension except increasing the depth as required to perform the installation.
3. The new electric hand-hole shall flush with the new concrete slab and be installed at the original location.